

98277

September 26, 1967

LOG OF WELL NO. 1, SURFCREST BEACH, WHIDBEY ISLAND, WASH.

DEPTH (feet)	DESCRIPTION
0-3	Sandy overburden
3-8	Sandy clay
8-53	Clay
53-60.5	Water sand
60.5-61.5	Gravelly hardpan
61.5-68	Water sand
68-72	Gravelly hardpan; bottom of well
5	Static water level

Well test: 20 gallons per minute

Driller: Whidbey Well Drillers
Rt. 2, Box 652
Oak Harbor, Wash. 98277

RECEIVED

JAN 9 1984

ISLAND COUNTY
HEALTH DEPARTMENT